

# OVERALL “TOTAL R” (THERMALLY BRIDGED) THERMAL PERFORMANCE CALCULATIONS TO AS/NZS 4859 Parts 1 & 2:2018

The following calculations by James M Fricker Pty Ltd are based upon:

- a) AS/NZS 4859.1:2018 “Thermal insulation materials for buildings. Part 1: General criteria and technical provisions”,
- b) AS/NZS 4859.2:2018 “Thermal insulation materials for buildings. Part 2: Design”,
- c) the Australian Institute of Refrigeration Air-conditioning & Heating (AIRAH) Handbook (Edition 5, 2013), and (if necessary) the ASHRAE Fundamentals Handbook.

AS/NZS 4859.2:2018 is a referenced document in NCC2019 & NCC2022.

Initial results report Total R for each thermal path. These results are combined by area weighting and isothermal planes method to deduce **Overall Surface Total R**. This is per AS/NZS 4859.2:2018 Clause 4.3 – “A total resistance associated with a construction of materials, computed or measured over an area sufficient to be fully representative of the element of construction, and specified as a Total R-value, including surface film resistances and thermal bridging.”

Total R-values are based on product in-service conditions in accordance with AS/NZS 4859.2:2018 including the alteration of insulation Material R for temperature, and Air Space R for temperature and infrared emittance.

Each calculation result is subject to any specific notes and assumptions listed on the calculation.

If a construction differs from the described system, the thermal resistance may be different.

All calculations were done by James M Fricker, F.AIRAH F.IEAust CPEng NER APEC Engineer IntPE(Aus), Registered Professional Engineer (Victoria PE0005355)



**ENGINEERS  
AUSTRALIA**  
Chartered Professional Engineer  
**MEMBER 1179647**



**JAMES M FRICKER** PTY LTD  
54 Felix Crescent  
Ringwood North VIC 3134 Australia  
Mobile: 0414 804 097  
Phone: (03) 9879 5744  
fricker@optusnet.com.au  
<http://fricker.net.au>

## ESTIMATION OF THE THERMAL RESISTANCE OF THE LOKPOD SYSTEM - LOKPOD 300 RAFT SLAB POD WITH VOID ABOVE REFLECTIVE GROUND BARRIER

The following determines Total Thermal Resistances (R-values) per AS/NZS 4859.1&2:2018, and "Added R".

**JMF Calc 556LP01**

The following uses the isothermal planes method to estimate the resulting combined R from the main thermal paths through the concrete/void LOKPOD system. The thermal elements considered to be within the isothermal planes are hilit with yellow in the table

The only insulating elements in the bare LOKPOD system are the voids between the inverted pods and the ground barrier.

WINTER R					SUMMER R				
Centre Post	Floor system element	t, mm	k	m <sup>2</sup> .K/W	Floor system element	t, mm	k	m <sup>2</sup> .K/W	
0.30% area.	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	300mm concrete	300	1.44	0.208	300mm concrete	300	1.44	0.208	
	LOKPOD 300 polypropylene	2	0.25	0.008	LOKPOD 300 polypropylene	2	0.25	0.008	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
	R sum between isothermal planes			0.841	R sum between isothermal planes			0.841	
4 Sides	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	300mm concrete	300	1.44	0.208	300mm concrete	300	1.44	0.208	
	2mm polypropylene	2	0.25	0.008	2mm polypropylene	2	0.25	0.008	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
	R sum between isothermal planes			0.841	R sum between isothermal planes			0.841	
Central Void	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	2mm polypropylene	2	0.25	0.008	2mm polypropylene	2	0.25	0.008	
	<b>Reflective air void</b>	<b>300</b>	<b>0.21</b>	<b>1.445</b>	<b>Reflective air void</b>	<b>300</b>	<b>0.75</b>	<b>0.399</b>	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
	R sum between isothermal planes			2.078	R sum between isothermal planes			1.032	

Combined R between isothermal planes  
(= 1/(A%/Ra + B%/Rb + C%/Rc))

winter

R1.70

summer

R1.00

**System R-values**

winter

R1.14

summer

R0.43

**LOKPOD 300 Thermal Resistance\*, base R =**

\*combined R with top 85mm concrete, without earth beneath

**Total R-values**

**LOKPOD 300 (with top 85mm concrete)**

with bare floor

with 6mm carpet and 15mm underlay

with 25mm mountain ash floating timber overlay

winter

R1.30

R1.71

R1.46

summer

R0.54

R0.95

R0.70

**ADDED R VALUES -**

**LOKPOD 300 (with reflective void beneath)**

winter

R1.08

summer

R0.37

**NOTES**

Determinations based upon AS/NZS 4859.1&2:2018, Thermal insulation materials for buildings.

The thermal components in the system are hilit in yellow and the bounding surfaces are taken as the isothermal planes for thermal bridging calculations.

The 1000 mm earth is included in the calcs to achieve the requisite isothermal plane, and then its value subtracted for the System & Total R results.

The reflective barrier top surface is assumed to have hemispherical infrared emittance of 0.04 to ASTM C1371.

If 25mm of extruded polystyrene is used as slab perimeter insulation, edge heat loss will be negligible.

This report may not be reproduced except in full. Results may not be quoted without reference to the assumptions.

**"Added R" is the thermal resistance addition due to the inclusion of the LOKPOD system to a base system only having an 85mm concrete slab.**

Calculated by James Fricker, F.AIRAH F.IEAust CPEng NER APEC Engineer IntPE(Aus)

Registered Professional Engineer (Victoria PE0005355)

Signed:




**ENGINEERS AUSTRALIA**  
Chartered Professional Engineer  
MEMBER 1179647

Calculation date 18/03/2024

556\_LOKPOD.xls

## ESTIMATION OF THE THERMAL RESISTANCE OF THE LOKPOD SYSTEM - LOKPOD 225 RAFT SLAB POD WITH VOID ABOVE REFLECTIVE GROUND BARRIER

The following determines Total Thermal Resistances (R-values) per AS/NZS 4859.1&2:2018, and "Added R".

**JMF Calc 556LPr02**

The following uses the isothermal planes method to estimate the resulting combined R from the main thermal paths through the concrete/void LOKPOD system. The thermal elements considered to be within the isothermal planes are hilit with yellow in the table

The only insulating elements in the bare LOKPOD system are the voids between the inverted pods and the ground barrier.

WINTER R					SUMMER R				
Centre Post	Floor system element	t, mm	k	m².K/W	Floor system element	t, mm	k	m².K/W	
0.30% area.	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	225mm concrete	225	1.44	0.156	225mm concrete	225	1.44	0.156	
	LOKPOD 225 polypropylene	2	0.25	0.008	LOKPOD 225 polypropylene	2	0.25	0.008	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
	R sum between isothermal planes			0.789	R sum between isothermal planes			0.789	
4 Sides	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	225mm concrete	225	1.44	0.156	225mm concrete	225	1.44	0.156	
	2mm polypropylene	2	0.25	0.008	2mm polypropylene	2	0.25	0.008	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
	R sum between isothermal planes			0.789	R sum between isothermal planes			0.789	
Central Void	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	2mm polypropylene	2	0.25	0.008	2mm polypropylene	2	0.25	0.008	
	<b>Reflective air void</b>	<b>225</b>	<b>0.16</b>	<b>1.390</b>	<b>Reflective air void</b>	<b>225</b>	<b>0.56</b>	<b>0.399</b>	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
	R sum between isothermal planes			2.023	R sum between isothermal planes			1.032	

Combined R between isothermal planes (= 1/(A%/Ra + B%/Rb + C%/Rc))	<b>winter</b>	<b>summer</b>
	<b>R1.64</b>	<b>R0.99</b>

	<b>winter</b>	<b>summer</b>
<b>System R-values</b>		
<b>LOKPOD 225 Thermal Resistance*, base R =</b>	<b>R1.07</b>	<b>R0.42</b>
<small>*combined R with top 85mm concrete, without earth beneath</small>		

	winter	summer
<b>Total R-values</b>		
<b>LOKPOD 225 (with top 85mm concrete)</b>		
with bare floor	<b>R1.23</b>	<b>R0.53</b>
with 6mm carpet and 15mm underlay	<b>R1.64</b>	<b>R0.94</b>
with 25mm mountain ash floating timber overlay	<b>R1.39</b>	<b>R0.69</b>

<b>ADDED R VALUES - LOKPOD 225 (with reflective void beneath)</b>	<b>winter</b>	<b>summer</b>
	<b>R1.01</b>	<b>R0.36</b>

**NOTES**

Determinations based upon AS/NZS 4859.1&2:2018, Thermal insulation materials for buildings.  
 The thermal components in the system are hilit in yellow and the bounding surfaces are taken as the isothermal planes for thermal bridging calculations.  
 The 1000 mm earth is included in the calcs to achieve the requisite isothermal plane, and then its value subtracted for the System & Total R results.  
 The reflective barrier top surface is assumed to have hemispherical infrared emittance of 0.04 to ASTM C1371.  
 If 25mm of extruded polystyrene is used as slab perimeter insulation, edge heat loss will be negligible.  
 This report may not be reproduced except in full. Results may not be quoted without reference to the assumptions.  
**"Added R" is the thermal resistance addition due to the inclusion of the LOKPOD system to a base system only having an 85mm concrete slab.**  
 Calculated by James Fricker, F.AIRAH F.IEAust CPEng NER APEC Engineer IntPE(Aus)  
 Registered Professional Engineer (Victoria PE0005355)

Signed:



Calculation date 18/03/2024  
556\_LOKPOD.xls

## ESTIMATION OF THE THERMAL RESISTANCE OF THE LOKPOD SYSTEM - LOKPOD 150 RAFT SLAB POD WITH VOID ABOVE REFLECTIVE GROUND BARRIER

The following determines Total Thermal Resistances (R-values) per AS/NZS 4859.1&2:2018, and "Added R".

**JMF Calc 556LP03**

The following uses the isothermal planes method to estimate the resulting combined R from the main thermal paths through the concrete/void LOKPOD system. The thermal elements considered to be within the isothermal planes are hilit with yellow in the table

The only insulating elements in the bare LOKPOD system are the voids between the inverted pods and the ground barrier.

WINTER R					SUMMER R				
Centre Post	Floor system element	t, mm	k	m².K/W	Floor system element	t, mm	k	m².K/W	
	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	150mm concrete	150	1.44	0.104	150mm concrete	150	1.44	0.104	
	LOKPOD 150 polypropylene	2	0.25	0.008	LOKPOD 150 polypropylene	2	0.25	0.008	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
0.30% area.	R sum between isothermal planes			0.737	R sum between isothermal planes			0.737	
4 Sides					SUMMER R				
4 Sides	Floor system element	t, mm	k	m².K/W	Floor system element	t, mm	k	m².K/W	
	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	150mm concrete	150	1.44	0.104	150mm concrete	150	1.44	0.104	
	2mm polypropylene	2	0.25	0.008	2mm polypropylene	2	0.25	0.008	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
14.70% area.	R sum between isothermal planes			0.737	R sum between isothermal planes			0.737	
Central Void					SUMMER R				
Central Void	Floor system element	t, mm	k	m².K/W	Floor system element	t, mm	k	m².K/W	
	85mm concrete	85	1.44	0.059	85mm concrete	85	1.44	0.059	
	2mm polypropylene	2	0.25	0.008	2mm polypropylene	2	0.25	0.008	
	<b>Reflective air void</b>	<b>150</b>	<b>0.11</b>	<b>1.308</b>	<b>Reflective air void</b>	<b>150</b>	<b>0.38</b>	<b>0.399</b>	
	Reflective barrier (facing up)	0	-	0.000	Reflective barrier (facing up)	0	-	0.000	
	1000mm earth	1000	1.6	0.625	1000mm earth	1000	1.6	0.625	
85.0% area.	R sum between isothermal planes			1.941	R sum between isothermal planes			1.032	
100% area.									

Combined R between isothermal planes (= 1/(A%/Ra + B%/Rb + C%/Rc))	<b>winter</b>	<b>summer</b>
	<b>R1.56</b>	<b>R0.97</b>

	<b>winter</b>	<b>summer</b>
<b>System R-values</b>		
<b>LOKPOD 150 Thermal Resistance*, base R =</b>	<b>R0.99</b>	<b>R0.41</b>
<small>*combined R with top 85mm concrete, without earth beneath</small>		

Total R-values		
	winter	summer
<b>LOKPOD 150 (with top 85mm concrete)</b>		
with bare floor	<b>R1.15</b>	<b>R0.52</b>
with 6mm carpet and 15mm underlay	<b>R1.56</b>	<b>R0.93</b>
with 25mm mountain ash floating timber overlay	<b>R1.31</b>	<b>R0.68</b>

ADDED R VALUES -		
	winter	summer
<b>LOKPOD 150 (with reflective void beneath)</b>	<b>R0.93</b>	<b>R0.35</b>

**NOTES**

Determinations based upon AS/NZS 4859.1&2:2018, Thermal insulation materials for buildings.  
 The thermal components in the system are hilit in yellow and the bounding surfaces are taken as the isothermal planes for thermal bridging calculations.  
 The 1000 mm earth is included in the calcs to achieve the requisite isothermal plane, and then its value subtracted for the System & Total R results.  
 The reflective barrier top surface is assumed to have hemispherical infrared emittance of 0.04 to ASTM C1371.  
 If 25mm of extruded polystyrene is used as slab perimeter insulation, edge heat loss will be negligible.  
 This report may not be reproduced except in full. Results may not be quoted without reference to the assumptions.  
**"Added R" is the thermal resistance addition due to the inclusion of the LOKPOD system to a base system only having an 85mm concrete slab.**  
 Calculated by James Fricker, F.AIRAH F.IEAust CPEng NER APEC Engineer IntPE(Aus)  
 Registered Professional Engineer (Victoria PE0005355)

Signed:



Calculation date 18/03/2024  
556\_LOKPOD.xls